

From: devcon.team@thameswater.co.uk <devcon.team@thameswater.co.uk>
Sent: 20 June 2025 16:04
To: Development Management - Planning <Planning@eastherts.gov.uk>
Subject: [External] 3rd Party Planning Application - 3/24/0966/OUT - ADDITIONAL INFO

East Hertfordshire District Council, Wallfields, , Hertford, Herts, SG13 8EQ

20 June 2025

Our DTS Ref: 76283
Your Ref: 3/24/0966/OUT - ADDITIONAL INFO

Dear Sir/Madam,

Re: LAND NORTH OF , A507 , WEST OF A10, BUNTINGFORD, Hertfordshire, SG9 9ER

Waste Comments:

Waste Comments:Thames Water has identified that the existing FOUL WATER network does not have sufficient capacity to support the proposed development. As such, we request that the following condition be attached to any planning permission granted:

The development shall not be occupied until confirmation is provided that either:

1. All necessary upgrades to the foul water network to accommodate additional flows from the development have been completed; or
2. A phasing plan for development and infrastructure, agreed with Thames Water and the Local Planning Authority, is in place. Where such a plan exists, no occupation shall occur other than in accordance with the approved phasing schedule.

Reason: Network reinforcement is likely to be required to support the proposed development. These upgrades are essential to avoid the risk of sewer flooding and pollution incidents.

If the Local Planning Authority considers this condition inappropriate or is unable to include it in the decision notice, it is essential to consult with Thames Water's Development Planning Department at Devcon.team@thameswater.co.uk before determining the application.

Please note where network modelling is required, Thames Water will need confirmation of outline planning permission, a development phasing plan, and evidence of land ownership to be submitted to devcon.team@thameswater.co.uk . Modelling can take 9-12 months to complete and will not commence until these have been provided.

We would expect the developer to demonstrate what measures will be undertaken to minimise groundwater discharges into the public sewer. Groundwater discharges typically result from construction site dewatering, deep excavations,

basement infiltration, borehole installation, testing and site remediation. Any discharge made without a permit is deemed illegal and may result in prosecution under the provisions of the Water Industry Act 1991. Should the Local Planning Authority be minded to approve the planning application, Thames Water would like the following informative attached to the planning permission: "A Groundwater Risk Management Permit from Thames Water will be required for discharging groundwater into a public sewer. Any discharge made without a permit is deemed illegal and may result in prosecution under the provisions of the Water Industry Act 1991. We would expect the developer to demonstrate what measures he will undertake to minimise groundwater discharges into the public sewer. Permit enquiries should be directed to Thames Water's Risk Management Team by telephoning 020 3577 9483 or by emailing trade.effluent@thameswater.co.uk . Application forms should be completed on line via www.thameswater.co.uk. Please refer to the Wholesale; Business customers; Groundwater discharges section.

The application indicates that SURFACE WATER will NOT be discharged to the public network and as such Thames Water has no objection, however approval should be sought from the Lead Local Flood Authority. Should the applicant subsequently seek a connection to discharge surface water into the public network in the future then we would consider this to be a material change to the proposal, which would require an amendment to the application at which point we would need to review our position.

Thames Water would advise that with regard to SURFACE WATER network infrastructure capacity, we would not have any objection to the above planning application, based on the information provided.

Water Comments:

Water Comments:With regard to water supply, this comes within the area covered by the Affinity Water Company. For your information the address to write to is - Affinity Water Company The Hub, Tamblin Way, Hatfield, Herts, AL10 9EZ - Tel - 0845 782 3333.

Supplementary Comments:

The application indicates the Southern end of the development will discharge surface water at peak flow discharge of 5.4 l/s to MH TL35297456 on the basis we have no objections. The Northern end of the development proposes to discharge to local ditches which eventually discharge to a local watercourse, this element will require approval from the LLFA.

Yours faithfully,
Development Planning Department

Development Planning,
Thames Water,
Maple Lodge STW,
Denham Way,
Rickmansworth,
WD3 9SQ,
Email: devcon.team@thameswater.co.uk

This is an automated email, please do not reply to the sender. If you wish to reply to this email, send to devcon.team@thameswater.co.uk